



Selection of Technologies

There is no “best” process of desalination.

The selection of a process is site specific and depends on several parameters, such as:

- Feed water quality
- Required quality of the produced water
- Plant's size and Location
- Land availability and Cost
- Energy availability
- Availability of technical staff




Unit site areas, for plants of 19,000 m³/d and larger

Process	Access and process building, m ² (ft ²)	Auxiliary equipment ¹ , m ² (ft ²)	Total area, m ² (ft ²)
Reverse osmosis			
Seawater	1,800 (19,375)	7,800 (83,959)	9,600 (103,334)
Brackish water	1,200 (12,917)	6,800 (73,195)	8,000 (86,111)
Electrodialysis			
ED	1,500 (16,146)	6,800 (73,195)	8,300 (89,340)
Distillation			
MSF	4,800 (51,667)	7,800 (83,959)	12,600 (135,625)
MED	6,000 (64,583)	7,800 (83,959)	13,800 (148,542)

¹ Assumes area for product water storage at 1-day production capacity, distribution system pumping, and electrical substation.


Source: Bureau of Reclamation, 2003



Source: Sommariva C., 2004




Relative Seawater Desalting Capital Costs (Metric)



Source: Bureau of Reclamation, 2003



Relative Brackish Water Desalting Capital Costs (Metric)



Source: Bureau of Reclamation, 2003



Key Data of the Processes

	MSF	MED	MED-TVC	MVC	RO	ED
Operating temperature (°C)	<120	<70	<70	<70 /1/	<45	<45
Form of main energy	Steam (heat)	Steam (heat)	Steam (heat)	Mechanical (electrical) energy	Mechanical (electrical) energy	Electrical energy
Thermal energy consumption (kWh/m ³) /4/	12	6 /5/	21 /5/	Not applicable	Not applicable	Not applicable
Electrical energy consumption (kWh/m ³)	3.5	1.5	1.5	8 – 14	4 – 7 /2/	1.0 /3/
Typical salt content of raw water (ppm TDS)	30,000 – 100,000	30,000 – 100,000	30,000 – 100,000	30,000 – 50,000	1,000 – 45,000	100 – 3,000
Product water quality (ppm TDS)	<10	<10	<10	<10	<500	<500
Current, typical Single-train capacity (m ³ /d)	5,000 – 70,000	500 – 12,000	100 – 25,000	10 – 2,500	1 – 10,000	1 – 12,000
/1/ In exceptional cases with acid dosing: 100 °C /2/ Seawater as raw water, otherwise lower consumption /3/ Depending on salt content in raw water: at 1,500 ppm TDS (add 0.5 kWh for every 1,000 ppm of removed ions) /4/ Expressed as the electrical energy that steam in a turbine-generator set cannot produce because of extraction from the process (performance ratio = 8 kg produced water per kg saturated steam in brine heater, resp. inlet steam ejector; steam pressure at inlet brine heater of MSF = 1.7 bara, at inlet first stage of MED = 0.4 bara, at inlet steam ejector of MED-TVC = 10 bara; pressure in "virtual" turbine condenser = 0.1 bara) /5/ At equal performance ratio and selected heating steam pressures, investment costs for MED plants are considerably higher than for MSF plants and investment costs for MED-TVC plants are lower than for MSF plants						

Source: Wangnick K. IDA Inventory, 2004



Classification based on Energy needs

